

DOCUMENT CODE
CP392-DDM-A1252.12



Master S.r.l., declares that:
CORNER TRANSMISSION
(art. A1252.12)

Passed the test of:
DURABILITY
25.000 cycle

On a test rig:
PNEUMATIC ACTUATOR

Passed the test according to:
UNI EN 1670:2007

Building hardware – Corrosion resistance – Requirements and test methods
ISO 9227:2006

Corrosion tests in artificial atmosphere – Salt spray tests

Classification:
240 hour – Grade 4 – Very high corrosion resistance

Service condition:
Service outdoors in exceptionally severe conditions where long-term protection of
product is required

Date of issue: 06/12/2016