

DOCUMENT CODE

CP559-DCM-1233.16



Master S.r.l., declares that:

Easy Rapid Plus 1233.16

Test mass 100 Kg

Test dimensions L x H

1500x800 (mm)

Passed test according to UNI EN 13126-6:

variable geometry stay hinges (with or without a friction stay)

25.000 cycles

Classification of variable stay hinge:

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion	Security	Application	Test size
1	2	3	4	5	6	7	8	9
-	5	100	0	1	5	0	6/1	1500/800

Date of issue: 13/07/2018