

**DOCUMENT CODE**

CP586-DCM-1231.12



**Master S.r.l., declares that:**

Easy Rapid 1231.12

Test mass 20 Kg

Test dimensions W x H

1200 x 450 (mm)

**Passed test according to UNI EN 13126-6:**

variable geometry stay hinges (with or without a friction stay)

25.000 cycles

**Classification of variable stay hinge:**

| Category of use | Durability | Mass | Fire resistance | Safety in use | Corrosion | Security | Application | Test size |
|-----------------|------------|------|-----------------|---------------|-----------|----------|-------------|-----------|
| 1               | 2          | 3    | 4               | 5             | 6         | 7        | 8           | 9         |
| -               | 5          | 020  | 0               | 1             | 5         | 0        | 6/1         | 1200/450  |

*Date of issue: 18/12/2018*