

DOCUMENT CODE
CP591-DDM-A1252.15



Master S.r.l., declares that:

CORNER TRANSMISSION

(art. A1252.15)

Passed the test of:

DURABILITY

25.000 cycle

On a test rig:

PNEUMATIC ACTUATOR

Passed the test according to:

UNI EN 1670:2007

Building hardware – Corrosion resistance – Requirements and test methods

ISO 9227:2006

Corrosion tests in artificial atmosphere – Salt spray tests

Classification:

240 hour – Grade 4 – Very high corrosion resistance

Service condition:

Service outdoors in exceptionally severe conditions where long-term protection of product is required

Date of issue: 18/12/2018