

DOCUMENT CODE

CP595-DCM-1292.18



**Master S.r.l., declares that:**

Easy Rapid 1292.18

**Passed test according to UNI EN 13126-6:**

variable geometry stay hinges (with or without a friction stay)

**Classification of variable stay hinge:**

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion	Security	Application	Test size
1	2	3	4	5	6	7	8	9
-	5	040	0	1	5	0	6/2 Side hung	800/1800
-	4	100	0	1	5	0	6/1 Top hung	1450/1450
-	4	100	0	1	5	0	6/1 Bottom hung	1450/1450

Date of issue: 18/12/2018