

DOCUMENT CODE
 CP613-SC-A6671.1

Master S.r.l., declares that:

Articles A6671.1 (one bearing nylon roller)

Passed the test according to:

**DURABILITY OF ROLLER FOR HORIZONTAL SLIDING WINDOWS AND
 DOORS**

25.000 cycles - Class 5 Sash mass 50 kg

On a test rig:

DRIVEN PNEUMATIC SYSTEM

According to:

UNI EN 13126-1: 2006

UNI EN 13126-15 :2008

Classification for rollers:

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion resistance	Security	Applicable part	Test size
1	2	3	4	5	6	7	8	9
-	5	025	0	1	5	-	15/1	-

Date of issue: 24/01/2019