

DOCUMENT CODE  
CP627-DDM-A3065



**Master S.r.l., declares that:**

“Italia” handle

art. A3065

**Passed the test of:**

DURABILITY 200.000 CYCLE (moveable handle)

**On a test rig:**

PNEUMATIC ACTUATOR

**According to:**

UNI EN 1906:2010

UNI EN 13126-1:2006

Building hardware - Lever handles and knob furniture - Requirements  
and test methods

**Classification for handles:**

Category of use	Durability	Mass	Fire resistance	Safety in use	Corrosion resistance	Security	Type of operation
1	2	3	4	5	6	7	8
4	7	-	0	1	4	-	A

*Date of issue: 12/02/2019*