



0407-CPR-518 (IG-042-2012) rev.5



## DECLARATION OF PERFORMANCE

02/2013

In conformity with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 march 2011 laying down harmonized conditions for the marketing of construction products and repealing Council Directive 89/106/ EEC

- 1. Identification code:** A8011
- 2. Type:** Dinamika hinge two-leaf, 67 mm inter-axe
- 3. Use:** single axis hinge for fire resistance doors class EI60 and on escape routes
- 4. Manufacturer:** Master S.r.l., s.p. 37 Conversano – Castiglione km 0,7 – 70014 Conversano (BA) Italy
- 5. Authorised representative:** N.A.
- 6. System of assessment:** system of assessment and verification of constancy of performance 1
- 7. Notified body:** Istituto Giordano S.p.A. NB 0407 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control according to system 1 and issued test report nr. 293085/6850/CPD. Istituto Giordano S.p.A. NB 0407 made the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control according to system 1 EC certificate of constancy of performance nr. 0407-CPR-518
- 8. N.A.**

**9. Declared performance:**

Essential characteristics	Performance	Harmonised technical specification
Safety: initial frictional torque	In conformity with grade 14	EN 1935:2002 + EN 1935:2002/AC:2003
Safety: static load	In conformity with grade 14	
Safety: overload	In conformity with grade 14	
Safety: shear load	N.P.D.	
Suitable to use on fire doors	Suitable	
Durability	In conformity with grade 14	
Corrosion resistance	Grade 4	
Dangerous substances	In conformity with regulation	

**10. The performance of the products identified in point 1 and 2 is in conformity with the declared performance in point 9**

**This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4**

*Signed for and on behalf of Master S.r.l.*

**Filippo Mola, Quality manager**



**Conversano, 09.04.2019**