



Istituto di Ricerca e Certificazione per le Costruzioni Sostenibili
Notified Body No. 1994 in accordance with Regulation CPR (EU) No. 305/2011

TEST REPORT

N. 0501/RP/2022

11 October 2022

Applicant

Master Italy s.r.l.
S.P.37 Conversano - Castiglione Km. 0,570 Z.I.
70014 Conversano (BA) - ITALY - C.P. 112

Tested sample

Tilt and turn mechanism,
trade name "KIT A/R WEEN HIDE 180 + DOOR SUPPORT"
(cf. description)

Executed tests

Durability
Rotation cycles
Additional loading test
Reveal test
Rebate-hindrance test
Corrosion test

Normative References

EN 13126-1:2011
EN 13126-8:2017
UNI EN 1670

**The report is done up of no. 13 pages and can be reproduced only integrally.
The results obtained refer exclusively to the samples tested.**

7.8 Overall grade of the arm with variable geometry

Durability	Mass	Corrosion	Test sizes
1	2	3	4
H2	150	4	1550x1400

Tab. 8. Overall grade

8 Photographs of the sample under test and of the experimental setup




Photo 1 Tested sample during the additional loading