



IRCCOS S.r.l.

Istituto di Ricerca e Certificazione per le Costruzioni Sostenibili

Notified Body No. 1994 in accordance with Regulation CPR (UE) No. 305/2011

TEST REPORT

N. 0337/RP/19

13th November 2019

Applicant

Master Italy S.r.l. con socio unico
S.P. 37 Conversano – Castiglione Km 0,570 – Zona Industriale
70014 Conversano (BA)

Tested sample

Tilt and turn mechanism for profiles for Euro-Groove Systems,
trade name “Anta Ribalta WEEN HIDE 110 ERRE”
(cf. description)

Executed tests

Durability
Rotation cycles
Additional loading test
Reveal test
Rebate-hindrance test
Corrosion resistance test

Normative References

EN 13126-1:2011
EN 13126-8:2017
EN 1670:2007 + AC:2008 – EN ISO 9227:2012

**The report is done up of no. 18 pages and can be reproduced only integrally.
The results obtained refer exclusively to the samples tested.**

7.9 Overall grade of the arm with variable geometry

Durability	Mass	Corrosion	Test sizes
1	2	3	4
H2	140	3	1550x1400

Tab. 9. Overall grade

8 Photographs of the sample under test and of the experimental setup



Photo 21. Tested sample in the experimental setup